

Guidelines and Specifications for:  
Fire Department Connection (FDC) Signs

- Sign shall be metal with red background and white reflective letters.
- Sign shall measure a minimum of 14" in height and 16" in width.
- The term "**FDC**" shall be illustrated with 6" capital letters with a 1" letter stroke.
- The **address** or **addresses** (number(s), street and suite if applicable) served by the connection shall be illustrated with 2" capital letters/numbers.
- The sign shall be mounted between 60" AFG from the bottom of sign and 80" AFG to the top of sign.
- For free standing connection, post mounted sign shall maintain a 36" clearance.

