

Notes:

1. The base for the curb & gutter shall be 4" of compacted VDOT 21A stone, which shall extend from the proposed edge of pavement to 1 foot behind the back of curb.
2. The back of the curb shall be backfilled with VDOT 21A stone up to 4" below the top of curb.

